

# **CROMMELINS™** GENERATORS

# **OPERATION & INSTRUCTION MANUAL**


Thank you for your selection of a CROMMELINS Generator.

This Operation Manual explains its use, installation, checking and maintenance. CROMMELINS suggest that you retain this manual for ready reference regarding proper handling of CROMMELINS Generator.









Phone: 1300 554 524
Freecall Fax: 1800 636 281
spareparts@crommelins.com.au
www.crommelins.com.au





Thank you very much for purchasing a **CROMMELINS**™GENERATOR.

This manual covers operation and maintenance of the **CROMMELINS**™GENERATOR.

This **CROMMELINS**™GENERATOR can be used in the agricultural, mining, construction, hire industries and general recreational appliances. With regards to DC application, the terminals are used only for charging 12 volt battery. Never use this generator for any other purpose.

Please take a moment to familiarise yourself with the proper operation and maintenance procedures in order to maximise the safe and efficient use of this product.

Keep this owner's manual at hand, so that you can refer to it at anytime.

Due to constant efforts to improve our products, certain procedures and specifications are subject to change without notice.

When ordering spare parts please always supply us with the model number, production number (prod no.) and serial number (ser no.) from your product.

Please fill in the following blanks after checking the production number and serial number on your product. (The location of these numbers, vary depending on product).

PROD NO.	
SER NO.	
Safety Precautions	
Symbols and Meanings	
Pre-operation Checks	
Operating Procedures	
Wattage Information	
Specifications Petrol Models	
Specifications Diesel Models	
Optional Parts	
Maintenance Schedule	
How –to Maintenance	
Periodic Operation and Inspection	
Transporting	
Preparation for Storage	

#### 1. SAFETY PRECAUTIONS

Please make sure you review each precaution carefully.

Pay special attention to statement preceded by the following words.

**A** WARNING

"WARNING" indicates a strong possibility of severe personal injury or loss

of life if instructions are not followed.

**A** CAUTION

"CAUTION" indicates a possibility of personal injury or equipment damage if instructions are not followed.

# **A** WARNING

Do not operate the generator near gasoline or gaseous fuel because of the potential danger of explosion or fire.

Do not fill the fuel tank with fuel while the engine is running. Do not smoke or use an open flame near the fuel tank. Be careful not to spill fuel during refuelling. If fuel is spilt, wipe it off and let dry before starting the engine.


# **A** WARNING

Do not place flammables near the generator.

Be careful not to place fuel, matches, gunpowder, oily cloths, straw, trash, or any other flammables near the generator.

# **A** WARNING

Do not operate the generator inside a room, cave, tunnel, or other insufficiently ventilated area. Always operate it in a well-ventilated area, otherwise the engine may become overheated, and the poisonous carbon monoxide gas, an odourless, colorless, poisonous gas, contained in the exhaust gases will endanger human lives. Operate generator only outdoors and far from open windows, doors, ventilation intakes and other openings. Keep the generator at least 1 meter (3 feet) away, including overhead, from any structure or building use.



# **A** WARNING

Do not enclose the generator nor cover it with a box.

The generator has a built-in forced air cooling system, and may become overheated if it is enclosed. If generator has been coved to protect it from the weather during non use, be sure to remove it and keep it well away from the area during generator use.

# **A** WARNING

Operate the generator on a level surface.

It is not necessary to prepare a special foundation for the generator. However, the generator will vibrate on an irregular surface, so choose a level place without surface irregularities.

If the generator is tilted or moved during operation, fuel may spill and /or the generator may tip over, causing a hazardous situation.

Proper lubrication cannot be expected if the generator is operated on a steep incline or slope. In such a case, piston seizure may occur even if the oil is above the upper level.

# **A** WARNING

Pay attention to the wiring or extension cords from the generator to the connected device. If the wire is under the generator or in contact with a vibrating part, it may break and possibly cause a fire, generator burnout, or electric shock hazard. Replace damaged or worn cords immediately.



# **A** WARNING

Do not operate in rain, wet or damp conditions, or with wet hands.

The operator may suffer severe electric shock if the generator is wet due to rain or snow.

# **A** WARNING

If wet, wipe and dry it well before starting. Do not pour water directly over the generator, nor wash it with water.


# **A** WARNING

Ensure all necessary electrical grounding procedures are followed during each and every use. Failure to do so can be fatal.


# **A** WARNING

Do not contact the generator to a commercial power line as connection may short circuit the generator and ruin it or cause electric shock hazard. Use the transfer switch for connecting to domestic circuit.

# **A** WARNING



Keep the area well-ventilated and keep open flames/sparks away when handling the battery



Engine becomes extremely hot during and for some time after operation.

Keep combustible material well away from generator area.

Be very careful not to touch any parts of the hot engine especially the muffler area or serious burns may result.



# **A WARNING**

Keep children and all bystanders at a safe distance from work areas.

# **A** WARNING

It is absolutely essential that you know the safe and proper use of the power tool or appliance that you intend to use. All operators must read, understand and follow the tool/appliance owner's manual. Tool and appliance applications and limitations must be understood. Follow all directions given on labels and warnings. Keep all instruction manuals and literature in a safe place for future reference.

# **A** WARNING

Use only 10AMP or 15AMP????? extension cords.

When a tool or appliance is used outdoors, use only extension cords marked "For Outdoor Use". Extension cords, when not in use should be stored in a dry and well ventilated area.

# **A** WARNING

Always switch off generator's AC circuit breaker and disconnect tools or appliances when not in use, before servicing, adjusting, or installing accessories and attachments.

# **A** CAUTION

Make sure the engine is stopped before starting any maintenance, servicing or repair. Make sure maintenance and repair of the generator are performed by properly trained personnel only.

## Symbols and Meanings

In accordance with the European requirements (eec Directives),the specified symbols as shown in the following table are used for the products and this instruction manual.

						33		
<u> </u>	D	Read the operator's instruction m		nanual.	<b>(b)</b>	Fire, open light and smoking prohibited.		
	Stay clear of the hot surface.					nnect the generator to percial power lines.		
	Exhaust gas is poisonous.  Do not operate in an unventilated in		i room.		Do not op	erate in rain or snow.		
$\triangle$	Stop the engine before refueling		ing.		Call for maintenance.			
Caution, risk of electric shock		k.	<b>8</b>	Keep dry.				
HOT, avoid touching the hot area.								
I	ON (pow	er and Engine)	₫	IN-position of a bistable push control		<b>©</b>	Engine start (Electric start)	
0	OFF (pow	er and Engine)	<b>(1)</b>	Protective earth (ground)		STOP	Engine stop	
~	Alteri	nating current	<del></del>	- Fuse			Gasoline	
===	Direc	t current	47	Engine oil		4	Fast	
+	Plus posit	; ive polarity		Add oil		-	Slow	
_	Minus	s ; tive polarity	= •	Battery charging condition			Fuel start / Open	
П	OUT-position of a bistable push control		N	Choke ; cold starting aid			Fuel stop / Close	
<b>P</b> r	Rated	l power (kW)	СОР	Continuous power		соѕФг	Rated power factor	
fr	Rated	frequency (Hz)	<b>U</b> r	Rated voltage (V)		<b>I</b> r	Rated current (A)	
<b>H</b> max		num site altitude e sea-level (m)	<b>7</b> max	Maximum ambient temperature (℃)		m	Mass (kg)	

#### 2. PRE-OEPERATION CHECKS

#### 1. CHECK ENGINE OIL

Before checking or refilling oil, be sure generator is located on stable and level surface with engine stopped.

- Remove oil filler cap and check the engine oil level.
- If oil level is below the lower level line, refill with suitable oil to upper level line.
- Do not screw in the oil filler cap when checking oil level.
- Change oil if contaminated.

#### 2. RECOMMENDED ENGINE OIL

Use 4-stroke automotive detergent oil of API service class SE or higher grade SG, SH or SJ recommended. SAE 10W-30 or 10W-40 is recommended for general, all-temperature use.

#### 3. CHECK ENGINE FUEL

#### **WARNING**

Do not refuel while smoking or near open flame or other such potential fire hazards. Otherwise fire accident may occur.

- Check fuel level at fuel level gauge
- If fuel level is low, refill with unleaded automotive gasoline.
- Be sure to use the fuel filter screen on the fuel filter neck.

#### WARNING

Make sure you review each of the warnings in order to prevent fire hazard.

- Do not refill tank while engine is running or hot.
- Before filling fuel, turn the engine switch into fuel stop/close position.
- Be careful not to allow dust, dirt, water or other foreign objects into fuel.
- Wipe off split fuel thoroughly before starting engine.
- Keep open flames away.

#### 4. CHECKING COMPONENT PARTS

Check the following items before starting engine.

- Fuel leakage from fuel hose, etc.
- Bolts and nuts for looseness.
- Components for damage or breakage.
- Generator not resting on or against any adjacent wiring.

#### 5. CHECK GENERATOR SURROUNDINGS

#### **WARNING**

Make sure you review each warning in order to prevent fire hazard.

- Keep area clear of flammables or other hazardous materials.
- Keep generator at least 1 meter away from buildings or other structures.
- Only operate generator in a dry, well ventilated area.
- Keep exhaust pipe clear of foreign objects.
- Keep generator away from open flames. NO SMOKING!
- Keep generator on a stable and level surface.
- Do not block generator air vents with paper or other material.

#### 6. GROUNDING THE GENERATOR

- To ground the generator to the earth, connect the grounding lug of the generator to the grounding spike driven into the earth or to the conductor which has been already grounded to the earth.
- If such grounding conductor or grounding electrode is unavailable, connect the grounding lug of the generator to the grounding terminal of the electric tool or appliance being used.

#### 7. BATTERY INSTALLATION – (Electric Start Models)

**Recommended Battery** 

- Type Lead-acid battery
- Capacity (Ah/5hr) 12V-21AH or more
- Size Less than 185(L) x 125(W) x 150(H) mm

#### **WARNING**

Death, personal injury and/or property damage may occur unless instructions are followed carefully.

- Use battery of recommended capacity.
- Turn the starter switch to the "O" (stop) position when mounting or dismounting battery. When mounting battery, connect the positive (+) cable first and then the negative (-) cable to the battery. Be careful not to short battery cables. When dismounting battery, disconnect negative (-) cable first.

RED CABLE – To positive (+) terminal BLACK CABLE – To negative (-) terminal

- Should a connection be made in an incorrect manner, the generator will not work.
- Ensure bolts and nuts are tightened on terminals securely so they will not be loosened by vibration.
- Disconnect battery cables when charging battery.

#### 3. OPERATING PROCEDURES

#### 1. STARTING THE GENERATOR

#### **CAUTION**

Check the oil level before each operation as outlined by the article "CHECK ENGINE OIL".

- a) Turn the engine switch to the position "I" (on).
- b) Turn the AC circuit breaker to the position "O" (off)
- c) Open the fuel valve.
- d) Set choke lever to close if the engine is cold.

#### e) Recoil starter model

Pull the starter handle slowly until passing the compression point (resistance will be felt), then return the handle to its original position and pull briskly.

- If the engine fails to start after several attempts, repeat above procedures with choke lever returned to "OPEN" position.
- Do not fully pull out the rope.
- After starting, allow the starter handle to return to its original position while still holding the handle.

#### f) Electric starter model

Insert the key into the key switch and turn it clockwise to the "I" (on) position to start the engine, turn the key further to the start position, the engine will be started by starting motor.

#### **CAUTION**

- Do not run the starting motor over 5 seconds continuously. If the engine fails to start, return the key to the "I" (on) position and wait about 10 second then start again.
- Do not turn the key switch to start position when the engine is running to prevent damage of starting motor.
- When starting the engine by recoil starter, set the key switch at the "I" (on) position and pull the starter handle.
- g) After the engine's started, return the choke lever gradually to "OPEN" position.
- h) Warm up the engine without load for a few minutes.

#### 2. STOPPING THE GENERATOR

- a) Turn off the power switch of the electric equipment and unplug the cord from receptacle of the generator.
- b) Allow the engine about 3 minutes to cool down at no-load before stopping.
- c) **Recoil starter model** Turn the engine switch to the position "O" (off). **Electric starter model** Turn the key switch to the STOP position.
- d) Close the fuel valve

### 3. OIL SENSOR

- a) The oil sensor detects the fall in oil level in the crankcase and automatically stops the engine when the oil level falls below a predetermined level.
- b) When engine has stopped automatically, switch off generator's AC circuit breaker, and check the oil level. Refill engine oil to the upper level as instruction on page 6 and restart the engine.
- c) If the engine does not start by usual starting procedures, check the oil level.

### 4. WATTAGE INFORMATION

Some appliances need a "surge" of energy when starting.

This means that the amount of electrical power needed to start the appliance may exceed the amount needed to maintain its use.

Electrical appliances and tools normally come with a label indicating voltage, cycles/Hz, amperage (amps) and electrical power needed to run the appliance or tool.

Check with your nearest dealer or service centre with questions regarding power surge of certain appliances or power tools.

- Electrical loads such as incandescent lamps and hot plates require the same wattage to start as is needed to maintain use.
- Loads such as fluorescent lamps require 1.2 to 2 times the indicated wattage during start-up.
- Loads for mercury lamps require 2 to 3 times the indicated wattage during start-up.
- Electrical motors require a large starting current. Power requirements depend on the type of motor and its use. Once enough "surge" is attained to start the motor, the appliance will require only 50% to 30% of the wattage to continue running.
- Most electrical tools require 1.2 to 3 times their wattage for running under load during use. For example, a 5,000 watt generator can power a 1800 to 40000 watt electrical tool.
- Loads such as submersible pumps and air compressors require a very large force to start. They need 3 to 5 times the normal running wattage in order to start. For example, a 5,000 watt generator would only be able to drive a 1,000 to 1,700 watt pump.

# 5. SPECIFICATIONS

MODEL		P30	P35	P62	P75	P85	P100E	
	Туре	Sincro, 2 Pole, Single Phase						
	Voltage regulating system	Capacitor						
Generator	AC Output Rated voltage-Frequency V-Hz	240 - 50						
Ger	Rated output VA (WA)	2100	2500	4700	5200	6200	7500	
	Maximum output VA (WA)	2400	2800	4960	6000	6800	8000	
	Rated power factor			0.8				
MODEL		EX17D	EX21D	EH36D	EX35D	EX40D	BS16	
	Туре	SUBARU Air-cooled, 4-stroke, Gasoline Engine					ie	
	Displacement mL	169	211	404	404	404	479	
	Fuel	Automotive Unleaded Gasoline						
	Fuel tank capacity L	12.8 (16.6)*1		7.0	22.0 (27.5)*1		8.4	
Engine	Engine oil capacity L	0.6		1.2	1.2		1.7	
ᇤ	Rated continuous operation H	10.5	9.0	8.5	7.5	6.6		
	Spark Plug	BR6HS Recoil (Ele		BPR6ES	BR6HS		RC12YC	
	Starting system			ectric Start Optional)			Recoil + Electric	
	¾ Load fuel consumption L/H	1.0	1.3	2.0	2.4	2.7	3.1	
	Noise Level (db@7m)	69	71		72	72		
	Direction of rotation	Counter - clockwise						
<u>_</u>	Length cm	71	71	85	85	85	80	
nsio	Width cm	45	45	50	50	50	50	
Dimension	Height cm	50	50	54	54	54	65	
٥	Dry weight kg	40	42	74	74	75	95	

# Specifications are subject to change without notice.

<sup>\*1: ( )</sup> shows the filled amount up to the "LEVEL" position.

# 6. SPECIFICATIONS

MODEL		D32E	D56	D69	D8EH	D8KEH		
	Туре	Sincro, 2 Pole, Single Phase						
Generator	Voltage regulating system	Capacitor						
	AC Output Rated voltage-Frequency V-Hz	240 - 50						
	Rated output VA (WA)	2200	2200 4100 4800		5000			
	Maximum output VA (WA)	2560	2560 4500 5500		6000			
	Rated power factor	0.8						
	MODEL	DY272D	DY41D	DY42D	1B40	KD500		
Engine	Туре		Air-cooled, d valve, dies	•	Hatz diesel engine	Kohler diesel engine		
	Displacement mL	265	412		462	505		
	Fuel	Automotive Diesel						
	Fuel tank capacity L	3.2 4.5			5.0			
	Engine oil capacity L	0.9	1.1		1.5			
	Rated continuous operation H							
	Starting system	Electric Start	Recoil Start (Electric Start Optional)		Electric Start	Electric Start		
	¾ Load fuel consumption L/H							
	Noise Level (db@7m)	76db	79db	79db	82db	80db		
	Direction of rotation	Counter-clockwise						
<u>_</u>	Length cm	71	86	86	92	92		
nsic	Width cm	45	52	52	71	71		
Dimension	Height cm	54	65	65	95	95		
	Dry weight kg	75	112	114	128	122		

#### 7. OPTIONAL PARTS

#### **Hire Pack Option**


- 2 Wheel kit
- Lifting handle
- Central lifting bar
- Weather proof outlets
- Circuit breakers
- Earth spike & lead
- Earth leakage switch

#### **Mine Spec Option for Petrol**

- Fire extinguisher
- Bunding
- Emergency stop
- Circuit breakers
- Earth spike & lead
- Battery isolator
- Earth leakage switch

#### **Mine Spec Option for Diesel**

- 2 x Weatherproof (IP66) outlets
- Electric start with sealed battery
- Earth leakage switch/RCD
- Earth stake & lead
- Circuit breakers
- Brushless Alternator
- 2 x Wheels with fold out handle
- 4 x Wheels (larger models)
- Central lifting point
- Emergency stop button
- Lockable battery isolator
- Bunding
- 1kg fire extinguisher
- Recoil lockout
- Anderson jump start plug
- (options vary depending on mine site)




#### **Electric Start Option**

- HD steel frame to suit e/start
- Starter motor, Key start
- Battery included

#### **Optional Extras for most Models**

- 2 or 4 Wheel kit
- · Carry handle
- Drip tray
- Long range fuel tank
- Anderson jump start plug
- Recoil lockout



### 8. MAINTENANCE SCHEDULE

DAILY	<ul> <li>Check oil level</li> <li>Check all components according to "PRE-OPERATION CHECKS."</li> </ul>
EVERY 50 HOURS	<ul> <li>Wash cleaner element more often if used in dirty/dusty environments.</li> <li>Check spark plug, clean if necessary.</li> </ul>
EVERY 100 HOURS	<ul> <li>Change engine oil. *- more often if used in dirty/dusty environments.</li> <li>Clean spark arrestor.</li> </ul>
EVERY 200 HOURS	<ul><li>Adjust spark plug gap.</li><li>Clean fuel strainer.</li></ul>
EVERY 500 HOURS	<ul> <li>Replace spark plug and cleaner element.</li> <li>Clean and adjust carburettor, valve clearance, and valve seat along with cylinder head.</li> </ul>
EVERY 1000 HOURS (24 MTHS)	<ul> <li>Inspect control panel parts.</li> <li>Check rotor and starter.</li> <li>Replace engine mount rubber.</li> <li>Overhaul engine.</li> <li>Change fuel lines.</li> </ul>

#### **NOTE:** (\*)

- Initial oil change should be performed after first twenty (20) hours of use. Thereafter change oil every 100 hours.
- Before changing oil, check for a suitable way to dispose of the old oil.
   Do not pour it down sewage drains, onto garden soil or into open streams.
   Your local zoning or environmental regulations will give you more detailed instruction on proper disposal.

### 9. "HOW-TO" MAINTENANCE

#### **CAUTION**

Make sure the engine is stopped before starting any maintenance, servicing or repair.

#### **NOTE**

It is recommended to use ear protection when performing operation, maintenance and repair of the generator set.

#### 1. ENGINE OIL CHANGE

- a) Change engine oil every 100 hours. (For new engine, change oil after 20 hours).
- b) Drain oil by removing the drain plug and the oil filler cap while the engine is warm.
- c) Reinstall the drain plug and fill the engine with oil until it reaches the upper level on the oil filler cap.
- d) Use fresh and high quality lubricating oil to the specified level as directed on page 6. If contaminated or deteriorated oil is used or the quantity of the engine oil is not sufficient, engine damage will result and its life will be greatly shortened.

#### 2. SERVICING THE AIR CLEANER

Maintaining an air cleaner in proper condition is very important.

Dirt induced through improperly installed, improperly serviced or inadequate elements causes damage and wears out the engine. Always keep the element clean.

- a) Remove the bolt of air cleaner cover.
- b) Remove the air cleaner cover and cleaner element.
- c) Urethane foam: wash urethane foam element in kerosene or diesel fuel. Then saturate the element in a mixture of 3 parts kerosene or diesel fuel and 1 part engine oil. Squeeze the element to remove the mixture and install it in the air cleaner.

#### **NOTE**

Instead of washing oil (kerosene), it is possible to wash the urethane foam element in a solution of mild detergent and warm water. Then rinse the element thoroughly in clean water. Allow the element to dry thoroughly. Soak the element in clean engine oil and squeeze out excel oil.

#### 3. CLEANING AND ADJUSTING SPARK PLUG

- a) If the plug is contaminated with carbon, remove it and clean it with a plug cleaner or wire brush.
- b) Adjust the electrode gap to 0.6 to 0.7mm (Spark Plug: BR6HS)

#### 4. CLEANING FUEL STRAINER

Dirt and water in the fuel are removed by the fuel strainer.

- a) Remove the strainer cup and throw away water and dirt.
- b) Clean the screen and strainer cup with gasoline.
- c) Tightly fasten the cup to main body, making sure to avoid fuel leak.

#### 10. PERIODIC OPERATION AND INSPECTION

When generator is used as an emergency electrical power source, periodic operation and inspection is required to ensure machine will operate when needed.

Fuel (gasoline/diesel) and engine oil will deteriorate overtime, and this may cause the engine to be difficult to start and will result in improper engine operation and fault.

#### **CAUTION**

Since the fuel (gasoline/diesel) will have deteriorated overtime, replace with fresh fuel periodically, every (3) months is recommended.

- a) Check the fuel (gasoline/diesel), engine oil and air cleaner.
- b) Start engine.
- c) With appliances such as lights activated, run the engine for over ten minutes.
- d) Check for the following:
  - Proper engine running.
  - Adequate output and the indicator lamp turned on properly.
  - The engine switch normally operated.
  - No leakage of engine oil and fuel (gasoline/diesel).

### 11. TRANSPORTING

When transporting the generator, make sure that the fuel (gasoline/diesel) is drained from the tank.

#### **WARNING**

- To prevent fuel spillage due to the vibration and impact, never transport the generator with the fuel (gasoline/diesel) filled in the tank.
- Secure the tank cap thoroughly.
- To avoid the risk of the gasoline flammability, never leave the generator in an area exposed to direct sunlight or high temperatures for a long time.
- Keep the fuel (gasoline/diesel) in the exclusive gasoline/diesel storage tank made by steel when transporting.
- a) Turn the engine switch to the "STOP" position.
- b) Drain the fuel from the tank.
- c) Secure the tank cap.

### CAUTION

- Do not place any heavy objects on the generator.
- Select and place the generator in the proper position of the transport vehicle so that the generator does not move or fall down. Fix the generator with rope were necessary.

#### 12. PREPARATION FOR STORAGE


The following procedures should be followed prior to storage of your generator for periods of 6 months or longer.

- Drain fuel from fuel tank carefully by disconnecting the fuel line. Gasoline/diesel left in the fuel tank will eventually deteriorate making engine starting difficult.
- Remove the carburettor float chamber and also drain the carburettor.
- Change engine oil.
- Check for loose bolts and screws, tighten them if necessary.
- Clean generator thoroughly with oiled cloth. Spray with preservative if available. (NEVER USE WATER TO CLEAN GENERATOR)
- Pull starter handle until resistance is felt, leaving handle in that position.
- Store generator in a well ventilated, low humidity area.

### 13. TROUBLE SHOOTING

When generator engine fails to start after several attempts, or if no electricity is available at the output socket, check the following chart. If your generator still fails to start or generate electricity, contact your nearest SUBARU engine dealer or service agent for further information or corrective procedures. To locate your nearest service agent go to www.crommelins.com.au.

#### When Engine Fails to Start:



#### **NO Electricity Is Generated at Receptacle:**

